

**VIK-HR d.o.o**

Božidarevićeva 9; HR-10000 Zagreb  
MB: 0171905

tel:+385 (0)1 23 13 060  
fax:+385 (0)1 23 32 036  
www.vik.hr  
vik@zg.t-com.hr



Podnositelj zahtjeva: **ASTRON BUILDINGS S.A.**  
Applicant: **LUXEMBOURG, L-9202 Diekirch,  
Route d'Ettelbruck, P.O Box 152**

## **SVJEDODŽBA O SUKLADNOSTI** **CERTIFICATE OF CONFORMITY S-L1-703028/11**

Proizvod: **LPR1000 KROV IZ ČELIČNIH HLADNO PROFILIRANIH LIMOVA**

Product: **LPR1000 ROOF, MADE OF COLD ROLLED SECTION STEEL**

Proizvođač: **ASTRON BUILDINGS S.A.**  
Manufacturer: **- LUXEMBOURG, L-9202 Diekirch, Route d'Ettelbruck, P.O Box 152  
- PŘEROV, CZECH REPUBLIC**

Izvešće o ispitivanju: **I-L1-703028/11**  
Test report

Kvaliteta čelika (EN 10326)

Steel quality (EN 10326)

Kvaliteta čelika (EN 10326)

Steel quality (EN 10326)

Ploča širine (mm)

Steel sheet width (mm)

Antikorozivna zaštita, obostrano g/m<sup>2</sup>

Corrosion protection, double-sided (g/m<sup>2</sup>)

Sloj boje: vanjska strana, μm

Paint layer on internal face μm

Visina glavnog rebra (mm) 38

Main rib height (mm)

S 550 GD, nazivne debljine 0,54/0,55 mm

S 550 GD, nominal thickness 0,54/0,55 mm

S 350 GD, nazivne debljine 0,62/0,63 mm

S 350 GD, nominal thickness 0,62/0,63 mm

1000 (3 modula od 333,3 mm)

1000 (3 modules 333,3 mm)

275 cink ili 150 alucink ili 255 galfan, donji sloj 8 epoksi

275 zinc or 150 aluzinc or 255 galfan, backcoating 8 epoxy

25 poliester, 35 poliester ili 25 PVDF/ 185 alucink obostrano

25 polyester, 35 polyester or 25 PVDF, 185 aluzinc doublesided

Visina sekundarnog rebra (mm) 3

Secondary rib height (mm)

Valjanost: **Pet godina, do 2012.03.28. uz kontrolu sukladnosti po isteku dvije god.**  
Certificate validity **Five years, until 2012.03.28. with a control testing after two years.**

### **ZAKLJUČAK/CONCLUSION**

Ovim se potvrđuje da značajke ispitanog proizvoda odgovaraju zahtjevima slijedećih propisa:

*It is certified hereby that the products characteristics are in conformity to the requirements of the following regulations:*

- Zakon o gradnji (NN RH br. 175/03)/Construction Law (NN RH br. 175/03)
- Tehnička dokumentacija proizvođača/Technical documentation supplied by the manufacturer

Zagreb, dana: 2007.03.28.  
Date



Odobrio:  
Authorized Person  
mr. Vladislav Špacir, dipl.ing.

Ova Svjedodžba je pravovaljana samo za ispitane uzorke kao i proizvode koji su izrađeni prema tehničkoj dokumentaciji kao i ispitni uzorci. Valjanost prestaje kada se izvrše promjene konstrukcije ili materijala, koje mogu utjecati na kakvoću i sigurnost proizvoda. *This certificate of conformity is valid only for products made according to the technical documentation same as for tested samples. Certificate becomes invalid when changes that can influence quality and safety of product are made on material and/or construction.*