

Podnositelj zahtjeva: **ASTRON BUILDINGS S.A.**  
Applicant: **LUXEMBOURG, L-9202 Diekirch,**  
**Route d'Ettelbruck, P.O Box 152**

## SVJEDODŽBA O SUKLADNOSTI

### CERTIFICATE OF CONFORMITY S-L1-703028/21

Proizvod: **"SINUTHERM" ZIDNI SENDVIČ PANELI IZ ČELIČNIH**  
**SINUSOIDALNIH LIMOVA ISPUNJENI POLIURETANSKOM PJENOM**  
Product: **"SINUTHERM" WALL SANDWICH PANELS MADE OF SINUSOIDAL**  
**STEEL PLATES, FILLED WITH POLYURETHANE FOAM**

Proizvođač: **ASTRON BUILDINGS S.A.**  
Manufacturer: **- LUXEMBOURG, L-9202 Diekirch, Route d'Ettelbruck, P.O Box 152**  
**- PREROV, CZECH REPUBLIC**

Izvešće o ispitivanju: **I-L1-703028/21**  
Test report

Kvaliteta čelika (EN 10326) Steel quality (EN 10326)	S320GD+Z275
Nazivna debljina čeličnog lima (mm) Nominal steel sheet thickness (mm)	0,63/0,70
Širina prekrivanja (mm) Overlay width (mm)	1000 (8 modula po 125 mm) 1000 (8 modules of 125 mm)
Nazivna debljina panela (mm) Panel nominal thickness (mm)	84
Prolaz topline (W/m <sup>2</sup> K) Heat transmission (W/m <sup>2</sup> K)	0,34
Antikorozivna zaštita Corrosion protection	275 cink ili 150 alucink ili 255 galfan obostrano + 25 µm poliester vanjski sloj 275 zinc or 150 aluzinc or 255 galfan bothsided + 25 µm polyester external layer

Valjanost: **Pet godina, do 2012.03.28. uz kontrolu sukladnosti po isteku dvije god.**  
Certificate validity **Five years, until 2012.03.28. with a control testing after two years.**

### ZAKLJUČAK

### CONCLUSION

Ovim se potvrđuje da značajke ispitnog proizvoda odgovaraju zahtjevima slijedećih propisa:  
It is certified hereby that the products characteristics are in conformity to the requirements of the following regulations:

- Zakon o gradnji (NN RH br. 175/03)/Construction Law (NN RH br. 175/03)
- Tehnička dokumentacija proizvođača/Technical documentation supplied by the manufacturer

Zagreb, dana: 2007.03.28.  
Date



Odobrio:  
Authorized Person  
mr. Vladislav Špacir, dipl.ing.

Ova Svjedodžba je pravovaljana samo za ispitane uzorke kao i proizvode koji su izrađeni prema tehničkoj dokumentaciji kao i ispitni uzorci. Valjanost prestaje kada se izvrše promjene konstrukcije ili materijala, koje mogu utjecati na kakvoću i sigurnost proizvoda.

This certificate of conformity is valid only for products made according to the technical documentation same as for tested samples. Certificate becomes invalid when changes that can influence quality and safety of product are made on material and/or construction.