

Podnositelj zahtjeva: **ASTRON BUILDINGS S.A.**  
*Applicant:* **LUXEMBOURG, L-9202 Diekirch,**  
**Route d'Ettelbruck, P.O Box 152**

## SVJEDODŽBA O SUKLADNOSTI

### CERTIFICATE OF CONFORMITY S-L1-703028/23

Proizvod: **LINER 1000/900/600 UNUTARNJA KROVNA OPLATA IZ**  
**ČELIČNIH HLADNO NISKOPROFILIRANIH LIMOVA**  
*Product:* **LINER 1000/900/600 ROOF INSIDE SKIN PLATE, MADE OF COLD**  
**ROLLED LOW DEPTH SECTION STEEL**

Proizvođač: **ASTRON BUILDINGS S.A.**  
*Manufacturer:* **- LUXEMBOURG, L-9202 Diekirch, Route d'Ettelbruck, P.O Box 152**  
**- PREROV, CZECH REPUBLIC**

Izvešće o ispitivanju: **I-L1-703028/23**  
*Test report*

Kvaliteta čelika (EN 10326)	S 280 GD
<i>Steel quality (EN 10326)</i>	<i>S 280 GD</i>
Nazivna debljina, mm	0,40
<i>Nominal thickness, mm</i>	<i>0,40</i>
Ploča širine (mm)	1000/ 900 / 600
<i>Steel sheet width (mm)</i>	<i>1000/ 900 / 600</i>
Antikoroziivna zaštita, obostrano g/m <sup>2</sup>	275 cink ili 150 alucink ili 255 galfan, donji sloj 8 epoksi
<i>Corrosion protection, double-sided (g/m<sup>2</sup>)</i>	<i>275 zinc or 150 aluzinc or 255 galfan, backcoating 8 epoxy</i>
Sloj boje: unutarnji μm	25 poliester, 35 poliester ili 25 PVDF/ 185 alucink obostrano
<i>Paint layer on internal surface μm</i>	<i>25 polyester, 35 polyester or 25 PVDF/ 185 aluzinc doublesided</i>

Valjanost: **Pet godina, do 2012.03.28. uz kontrolu sukladnosti po isteku dvije god.**  
*Certificate validity* **Five years, until 2012.03.28. with a control testing after two years.**

### ZAKLJUČAK/CONCLUSION

Ovim se potvrđuje da značajke ispitivanog proizvoda odgovaraju zahtjevima slijedećih propisa:  
*It is certified hereby that the products characteristics are in conformity to the requirements of the following regulations:*

- Zakon o gradnji (NN RH br. 175/03)/*Construction Law (NN RH br. 175/03)*
- Tehnička dokumentacija proizvođača/*Technical documentation supplied by the manufacturer*

Zagreb, dana: 2007.03.28.  
*Date*



Odobrio:  
*Authorized Person*  
mr. Vladislav Špacir, dipl.ing.

Ova Svjedodžba je pravovaljana samo za ispitane uzorke kao i proizvode koji su izrađeni prema tehničkoj dokumentaciji kao i ispitni uzorci. Valjanost prestaje kada se izvrše promjene konstrukcije ili materijala, koje mogu utjecati na kakvoću i sigurnost proizvoda.

*This certificate of conformity is valid only for products made according to the technical documentation same as for tested samples. Certificate becomes invalid when changes that can influence quality and safety of product are made on material and/or construction.*