

Podnositelj zahtjeva: **ASTRON BUILDINGS S.A.**  
 Applicant: **LUXEMBOURG, L-9202 Diekirch,**  
**Route d'Ettelbruck, P.O Box 152**

## SVJEDODŽBA O SUKLADNOSTI

### CERTIFICATE OF CONFORMITY S-L1-703028/5

Proizvod: **"EUROTEC" ZID SA I BEZ "ASTROTERM" IZOLACIJE IZ ČELIČNIH HLADNO PROFILIRANIH LIMOVA**

Product: **"EUROTEC" WALL WITH AND WITHOUT "ASTROTERM" INSULATION, MADE OF COLD ROLLED SECTION STEEL**

Proizvođač: **ASTRON BUILDINGS S.A.**

Manufacturer: **- LUXEMBOURG, L-9202 Diekirch, Route d'Ettelbruck, P.O Box 152**  
**- PŘEROV, CZECH REPUBLIC**

Izveštje o ispitivanju: **I-L1-703028/5**  
 Test report

Kvaliteta čelika (EN 10326)	S250	Sloj boje: vanjski $\mu\text{m}$	25 PVDF
Steel quality (EN 10326)	GD	Paint layer on external surface $\mu\text{m}$	
Nazivna debljina čeličnog lima (mm)	0,65	Sloj boje: unutarnji $\mu\text{m}$	3 primer i 5 epoksi
Nominal steel sheet thickness (mm)		Paint layer on internal surface $\mu\text{m}$	3 primer and 5 epoxy
Širina prekrivanja (mm)	400	Nazivna debljina panela zida (mm)	40, 80, 100, 120
Overlay width (mm)		Wall panel nominal thickness (mm)	
Visina rebra (mm)	80	Izolacija, gustoća ( $\text{kg}/\text{m}^3$ )	16
Rib height (mm)		Insulation density ( $\text{kg}/\text{m}^3$ )	
Izolacija, koeficijent toplinske vodljivosti (W/mK)	0,036		
Insulation, thermal conductivity coefficient (W/mK)			
Antikorozivna zaštita čelične ploče, obostrano $\text{g}/\text{m}^2$	275 cink ili 150 alucink ili 255 galfan		
Steel plate corrosion protection, double-sided $\text{g}/\text{m}^2$	275 zinc or 150 aluzinc or 255 galfan		

Valjanost: **Pet godina, do 2012.03.28. uz kontrolu sukladnosti po isteku dvije god.**  
 Certificate validity **Five years, until 2012.03.28. with a control testing after two years.**

### ZAKLJUČAK

### CONCLUSION

Ovim se potvrđuje da značajke ispitivanog proizvoda odgovaraju zahtjevima slijedećih propisa:  
 It is certified hereby that the products characteristics are in conformity to the requirements of the following regulations:

- Zakon o gradnji (NN RH br. 175/03)/Construction Law (NN RH br. 175/03)
- Tehnička dokumentacija proizvođača/Technical documentation supplied by the manufacturer

Zagreb, dana: 2007.03.28.  
 Date



Odobrio:  
 Authorized Person  
 mr. Vladislav Špacir, dipl.ing.

Ova Svjedodžba je pravovaljana samo za ispitane uzorke kao i proizvode koji su izrađeni prema tehničkoj dokumentaciji kao i ispitni uzorci. Valjanost prestaje kada se izvrše promjene konstrukcije ili materijala, koje mogu utjecati na kakvoću i sigurnost proizvoda.

This certificate of conformity is valid only for products made according to the technical documentation same as for tested samples. Certificate becomes invalid when changes that can influence quality and safety of product are made on material and/or construction.