

Podnositelj zahtjeva: **ASTRON BUILDINGS S.A.**
 Applicant: **LUXEMBOURG, L-9202 Diekirch,**
Route d'Ettelbruck, P.O Box 152

SVJEDODŽBA O SUKLADNOSTI

CERTIFICATE OF CONFORMITY S-L1-703028/7

Proizvod: **PA/LPA900 - ZIDNI SISTEM, SA I BEZ "ASTROTERM" IZOLACIJE**

Product: **PA/LPA900 - WALL, WITH AND WITHOUT "ASTROTERM" INSULATION**

Proizvođač: **ASTRON BUILDINGS S.A.**
 Manufacturer: **- LUXEMBOURG, L-9202 Diekirch, Route d'Ettelbruck, P.O Box 152**
- PREROV, CZECH REPUBLIC

Izvešće o ispitivanju: **I-L1-703028/7**
 Test report

Kvaliteta čelika (EN 10326)	S350GD	Ploča širine (mm)	900
Steel quality (EN 10326)		Steel sheet width (mm)	
Nazivna debljina lima (mm)	0,49	Visina rebra (mm)	29
Nominal steel plate thickness (mm)		Rib height (mm)	
Antikoroziivna zaštita, obostrano g/m ²		275 cink ili 150 alucink ili 255 galfan	
Corrosion protection, double-sided (g/m ²)		275 zinc or 150 aluzinc or 255 galfan	
Sloj boje: unutarnji μm		3 primer i 5 epoksi	
Paint layer on internal surface μm		3 primer and 5 epoxy	
Sloj boje: vanjski μm		25/35 poliester ili 25 PVDF	
Paint layer on external surface μm		25/35 polyester or 25 PVDF	
Izolacija, gustoća 16 kg/m ³		koeficijent toplinske vodljivosti 0,036 W/mK	
Insulation density 16 kg/m ³		thermal conductivity coefficient 0,036 W/mK	
Nazivna debljina izolacije (norma EN 13162)		40, 50, 60, 80, 100, 120	
Insulation nominal thickness (EN 13162 standard)			

Valjanost: **Pet godina, do 2012.03.28. uz kontrolu sukladnosti po isteku dvije god.**
 Certificate validity **Five years, until 2012.03.28. with a control testing after two years.**

ZAKLJUČAK

CONCLUSION

Ovim se potvrđuje da značajke ispitivanog proizvoda odgovaraju zahtjevima slijedećih propisa:
 It is certified hereby that the products characteristics are in conformity to the requirements of the following regulations:

- Zakon o gradnji (NN RH br. 175/03)/Construction Law (NN RH br. 175/03)
- Tehnička dokumentacija proizvođača/Technical documentation supplied by the manufacturer

Zagreb, dana: 2007.03.28.
 Date



Odobrio:
 Authorized Person
 mr. Vladislav Špacir, dipl.ing.

Ova Svjedodžba je pravovaljana samo za ispitane uzorke kao i proizvode koji su izrađeni prema tehničkoj dokumentaciji kao i ispitni uzorci. Valjanost prestaje kada se izvrše promjene konstrukcije ili materijala, koje mogu utjecati na kakvoću i sigurnost proizvoda. This certificate of conformity is valid only for products made according to the technical documentation same as for tested samples. Certificate becomes invalid when changes that can influence quality and safety of product are made on material and/or construction.