

Podnositelj zahtjeva: **ASTRON BUILDINGS S.A.**
 Applicant: **LUXEMBOURG, L-9202 Diekirch,**
Route d'Ettelbruck, P.O Box 152

SVJEDODŽBA O SUKLADNOSTI

CERTIFICATE OF CONFORMITY S-L1-703028/8

Proizvod: **"ASTROTEC" KROV SA I BEZ IZOLACIJE IZ ČELIČNIH
HLADNO PROFILIRANIH LIMOVA**
 Product: **"ASTROTEC" WITH OR WITHOUT INSULATION, MADE OF
COLD ROLLED SECTION STEEL**

Proizvođač: **ASTRON BUILDINGS S.A.**
 Manufacturer: **- LUXEMBOURG, L-9202 Diekirch, Route d'Ettelbruck, P.O Box 152**
- PŘEROV, CZECH REPUBLIC

Izješće o ispitivanju: **I-L1-703028/8**
 Test report

Kvaliteta čelika (EN 10326) <i>Steel quality (EN 10326)</i>	S350GD	Visina rebra (mm) <i>Rib height (mm)</i>	76
Nazivna debljina čeličnog lima (mm) <i>Nominal steel sheet thickness (mm)</i>	0,63 ili 0,75	Nazivna debljina panela (mm) <i>Panel nominal thickness (mm)</i>	50, 60, 80, 100, 120
Širina prekrivanja (mm) <i>Overlay width (mm)</i>	600		
Koeficijent prelaza topline (W/m ² K) <i>Thermal conductivity coefficient (W/m²K)</i>			0,85; 0,65; 0,42; 0,42; 0,39
Antikorozivna zaštita obostrano g/m ² <i>Corrosion protection double-sided g/m²</i>		185 alucink 185 aluzink	

Valjanost: **Pet godina, do 2012.03.28. uz kontrolu sukladnosti po isteku dvije god.**
 Certificate validity **Five years, until 2012.03.28. with a control testing after two years.**

ZAKLJUČAK CONCLUSION

Ovim se potvrđuje da značajke ispitnog proizvoda odgovaraju zahtjevima slijedećih propisa:
 It is certified hereby that the products characteristics are in conformity to the requirements of the following regulations:

- Zakon o gradnji (NN RH br. 175/03)/Construction Law (NN RH br. 175/03)
- Tehnička dokumentacija proizvođača/Technical documentation supplied by the manufacturer

Zagreb, dana: 2007.03.28.
 Date



Odobrio:
 Authorized Person
 mr. Vladislav Špacir, dipl.ing.

Ova Svjedodžba je pravovaljana samo za ispitane uzorke kao i proizvode koji su izrađeni prema tehničkoj dokumentaciji kao i ispitni uzorci. Valjanost prestaje kada se izvrše promjene konstrukcije ili materijala, koje mogu utjecati na kakvoću i sigurnost proizvoda.

This certificate of conformity is valid only for products made according to the technical documentation same as for tested samples. Certificate becomes invalid when changes that can influence quality and safety of product are made on material and/or construction.